

*WLD*

405803

Resident Engineer JS

884

Chief Project Engineer Building 419 - Gantry Crane

*R*

March 1, 1954

With reference to your memorandum No. OS 7539 dated February 12, 1954, the Crane Hoist Engineering Corp. has been contacted and we are attaching a copy of their letter outlining their recommendations. As mentioned in a previous teletype, a spare load brake has been ordered and will be used to replace the existing load brake in the gantry crane. Since these load brakes are interchangeable with brakes furnished on similar equipment by the Crane Hoist Engineering Corp., this solution will provide the jobsite with a spare unit to take care of future failures should they occur.

Original signed by  
H. L. DIETZE

David L. Harver, Jr.  
Chief Project Engineer

DLNjr:HLD:cas  
Enc. 1

cc: Project Manager JS  
Constr.-Oper. Div. (2)  
Project Engineering File ✓  
751 Mail Room (2)

REPOSITORY NATIONAL ARCHIVES  
PACIFIC SOUTHWEST REGION

COLLECTION RG 326 ATOMIC ENERGY COMMISSION

BOX No. 199624 (#608) A16334 326-65V0170  
ELMER GENERAL

FOLDER JOB 884 PROJECT ENGINEERING FILE

BEST COPY AVAILABLE

*[Faint circular stamp]*

1161