

Project: *SECRET*

~~CONFIDENTIAL~~

10/1/53

R. A. Boettcher

I. B. Mc Daniel Station 1200 - Revisions to  
8 September 1953

R

I have to report that the second pour of station 1200 was completed yesterday, September 7th. After the pour was completed three revision plans were issued.

Plan 6201 with Revision 1, Plan 6202 to Revision 2 and Plan 6231 with Revision 1 were the plans issued. Our practice here is to check revisions when new prints are received. As we had these revisions, the new prints were ordered. Fortunately, one of our inspectors (Mr. Tom Clark) with his customary strict attention to detail noted the following differences:

- (a) Plan 6201. The date in title has been changed. By adding a loop above zero, the date has been changed from 8/20/53 to 8/27/53. The drawing shows that the inside width of the intake chamber was changed from 2'-8" to 2'-5" without special note on plan.
- (b) Plan 6202 - Date in box has been altered from 8/21/53 to 8/27/53. On detail 14 the diameter has been changed from 2'-1" to 2'-5".
- (c) Plan 6231 - Date in box has been altered similar to (b) above. Elevation D notes a box dimension for the intake filters as 4'-0 1/2" instead of 4'-0".

As stated above, the second pour has been completed, dowels are set for the third pour and it is proposed to proceed as follows:

- (1) Hold width of chamber to 2'-8".
- (2) Hold diameter for filters at 4'-0".

I feel this alteration of revisions is a very serious matter and should be referred to the same Office. If this procedure is not immediately corrected it will cause confusion and conflicts in the field.

Approval of action taken is recommended.

THIS COPY AVAILABLE

DEPARTMENT OF INTERIOR	
SINGLE REVIEW AUTHORITY	
REVIEWER (ADD):	NAME: <i>J. D. LRS</i>
DATE: <i>8/11/53</i>	

*[Handwritten signature]*

INITIALS

C. T. Falt

~~SECURITY~~

RESTRICTED

*[Faint handwritten notes and signatures]*